



Karnataka State Fire

And Emergency Services

No: 333/CFO/KLB/ZONE/FSR/2021

Dated: 09-09-2021

To,

The Secretary
Bujari & Biradar B.Ed. College
& Nagaraj Bujari Higher Primary School Afzalpur
Under Shree Paripoorna
Education & Rural Development Society *
Sindagi Branch Gulbarga Road,
Afzalpur Tq: Afzalpur
Dist: Kalaburagi-585301
Sir,

ATTESTED

S. J. GUTTA

ADVOCATE & NOTARY
AFZALPUR-585301 Dist. Kalaburagi



Sub:-Issue of "Fire Safety Recommendations" on requirement of fire Prevention fire fighting and evacuation measures required At Bujari & Biradar B. Ed. College & Nagaraj Bujari Higher Primary School Afzalpur Under Shree Paripoorna Education & Rural Development Society * Sindagi Branch: Gulbarga Road, Afzalpur Tq: Afzalpur Dist: Kalaburagi-585301.

Ref :-1) Applicants letter on Date: 18/08/2021.
2) C.No.82/DFO/KLB/2021, Date 08/09/2021

With reference to the subject above cited, the premises of Bujari & Biradar B.Ed. College & Nagaraj Bujari Higher Primary School Afzalpur Under Shree Paripoorna Education & Rural Development Society @ Sindagi Branch: Gulbarga Road, Afzalpur Tq: Afzalpur Dist: Kalaburagi-585301, inspected by, District Fire Officer, Kalaburagi on 03/09/2021 with respect to fire prevention, fire fighting and evacuation measures to be Provided in the above premises and Submitted building details as under

A. Details of the building / premises :-

01	Name and Address of the Applicant.	The Secretary Bujari & Biradar B.Ed. College & Nagaraj Bujari Higher Primary School Afzalpur Under Shree Paripoorna Education & Rural Development Society * Sindagi Branch: Gulbarga Road, Afzalpur Tq: Afzalpur Dist: Kalaburagi-585301.
02	Name and Address of the premises.	Bujari & Biradar B.Ed. College & Nagaraj Bujari Higher Primary School Afzalpur Under Shree Paripoorna Education & Rural Development Society @ Sindagi Branch: Gulbarga Road, Afzalpur Tq: Afzalpur Dist: Kalaburagi-585301.
03	Name and address of the Building owner	The Secretary Bujari & Biradar B.Ed. College & Nagaraj Bujari Higher Primary School Afzalpur Under Shree Paripoorna Education & Rural Development Society @ Sindagi Branch: Gulbarga Road, Afzalpur Tq: Afzalpur Dist: Kalaburagi-585301.

ATTESTED

S. J. GUTTA
ADVOCATE & NOTARY
AFZALPUR-585301, Dist. Kalaburagi



		Nos. of riser per flight	: 13 risers provided in a flight
		Height of handrails	: 1 Mtrs.
		Head room clearance	: 02.25 Mtrs.
06	Fire extinguisher	Provided 02 no ABC fire extinguishers Each of 04.5 Kgs capacity.	Recommended to Provide 01) 4.5 kg capacity of 01 No's ABC Fire extinguisher for each 03 no's of class room. 02) 4.5 kg capacity of 02 No of CO2 Fire extinguisher near the Electrical Switch board. 03) 06 No's of sand Bucket for Electrical board. 04) 5 kg capacity of 01 No of DCP Fire extinguisher for libaray. 05) Two number of Hand gloves near the Electrical Switch board. [All the extinguishers suggested above should be with B.I.S. markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically].
07	Public address system	Not provided	Recommended to Provided Public address system with two way communication facility at each floor of this building with its 'control' at the ground floor level.
08	Safe assembly area	Not provided	Recommended to safe Assemble area at the strategic location and ear marked the area and the direction for the assemble area must lead from the class rooms to the assemble area. There must be to doorways exist for each class rooms.
09	First aid	Not provided	Recommended to provided First aid kit at each floor near the staircase.
10	Hose reel hose.	Not provided	Recommended to Provide Hose reel hose system near the staircases connected to terrace tank of 10000 lts capacity and the system connected to electrical driven pump of discharge capacity 450 LPM
11	Terrace tank Or Over Head Tank	Not provided	Recommended to provide terrace tank (RCC structure) of 10,000 ltrs water capacity for each down comer & hose reel hose system.
12	Underground static water storage tank combined capacity for wet-riser, yard hydrant and sprinklers per set of pumps.	Provided 10,000 ltrs capacity of water	Adequate
13	Fire Control Room At Ground Floor	Not Provided.	Recommended to provide Separate Fire Control Room at Ground Floor Reception Counter.
14	Escape routes Sinages (SIGN BOARDS)	Not Provided.	Recommended to provide The (EXIT SIGN BOARD) throughout the building for showing the Directions in which the



			Students have to move in the event of any emergency. The safe assemble area to be earmarked at the strategic location.
15	Fire prevention measures	Not provided	<ol style="list-style-type: none"> 1) Explosive and Inflammable materials Should not be stored In the premises. 2) Accumulation of Combustible waste in And around the premises Should be avoided 3) The class room and other door shall not be Kept locked /latched During working hoursAnd shall be free from Obstructions. 4) C.C. cameras so provided all around the school building at the strategic location to be maintained. 5) On site and off site emergency plans must be prepared the mock evacuation drill must be conducted twice a year.
16	Fire order	Not provided	Recommended to provide Notice boards indicating with Details of action to be taken by the employees in case of an Emergency/fire has been displayed with telephone Number of Afzalpur Fire Station i.e.08470-283101 & 101 and of near by Ambulance Service.
	Fire fighting training	Not provided	Recommended to 40% of the employees should be got trained in the Fire prevention & fire fighting at the R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore . Within 6 month of date of issue this recommendations

Hence this "Fire Safety Recommendation" is issued to Bujari & Biradar B.Ed. College & Nagaraj Bujari Higher Primary School Afzalpur Under Shree Paripoorna Education & Rural Development Society @ Sindagi Branch: Gulbarga Road, Afzalpur Tq: Afzalpur Dist: Kalaburagi-585301.subject to strict adherence of the conditions as laid down in this Recommendations and to check the portable fire extinguishers and to conduct mock drills periodically And the management must not extend the height of the building beyond 15.0 meters. and this Recommendations is valid for a period of one year from the date of issue.

Your's faithfully

[Signature]

**CHIEF FIRE OFFICER
KARNATAKA FIRE AND
EMERGENCY SERVICES
KALABURAGI ZONE
KALABURAGI-585103.**

ATTESTED

S. J. C

ADVOCATE &
AFZALPUR-585301 DIST: KALABURAGI

AFZALPUR
KALABURAGI
585301
2020
2025

Copy to: The District Fire Officer Kalaburagi.